

Lac La Biche County Water Servicing Guidelines

1. General

- a. Appropriate permits as well as permission to connect to municipal services must be obtained from Lac La Biche County prior to commencing any work. Appropriate fees must be paid in full.
- b. A water and sewer Service Completion Notification must be completed and faxed or emailed before the water and sewer service will be turned on.**
- c. Each lot must have a separate water and sewer service as per the Plumbing Code.
- d. All trenching and backfilling should be completed in strict conformance with Occupational Health and Safety regulations and all other applicable regulations, and under the direction of Lac La Biche County.
- e. It is the lot owner's responsibility to ensure that all underground utilities have been located prior to commencement of work. Locates can be obtained through Alberta One Call at 1-800-242-3447 or via the internet at <http://www.albertaonecall.com/submit-a-locate-request/>.
- f. All contractors hired by the property owner should be certified for such work as per the Alberta Plumbing Codes and the Alberta Standard of Practice for Private Sewage.
- g. It is the lot owner's responsibility to ensure that all piping system connections are thoroughly flushed prior to connecting to any mechanical device which may be damaged by debris accumulated during construction.
- h. Piping should be buried below the frost depth (9 feet or 2.75 metres). Where minimum cover cannot be attained, provisions shall be made for frost protection.
- i. Water service piping should be Plumbing Code approved. Minimum pipe diameter is 20 mm or $\frac{3}{4}$ inch.
- j. All underground connections must be Plumbing Code approved.
- k. Every connection to municipal services shall be inspected and flushed by County staff.
- l. Settlement of excavations shall be repaired by the property owner within 1 year of connection.
- m. All piping and equipment (except the water meter) from the municipal connection to the building are the responsibility of the property owner.

2. Trickle Water System

- a. Trickle water mains are restricted to 2 gallons per minute. A cistern will be required for each property. This cistern will be set back from the roadway and at an elevation that maintains positive pressure.
- b. Meter chambers may be required at the discretion of the Utilities Manager.
- c. Meter chambers, with required flow restrictors and backflow preventers may be supplied, at the owners cost, from the county.
- d. Meter chambers shall be installed, when required, 5 feet (1.5 meters) inside the property line and a minimum of 6 ½ feet (2 meters) from the shoulder of a driveway.
- e. Meter chambers shall be set level on a firm base, such as a concrete sidewalk pad, and backfilled with clean material.
- f. Only Plumbing Code approved fittings will be permitted to connect service lines to the meter chamber. This line will then extend to the cistern.
- g. If a meter chamber is not required, the service line shall run directly from the municipal connection into the building being served. This service line shall have a valve, backflow preventer and flow restrictor installed PRIOR to the water meter. No other connections are permitted prior to the meter. This line will then extend to the cistern.
- h. Each cistern will require an approved float switch, installed as per Plumbing Code requirements, to control the water level.
- i. All connections must be inspected PRIOR to backfilling any aspect of the system.
- j. All penetrations into a cistern must be made via factory-installed hubs or fittings, or through a cored opening that has been adequately sealed.
- k. All service lines must be flushed by municipal staff prior to being utilized. No services may be turned on by anyone other than municipal staff.
- l. The remote water meter wiring shall be provided by the municipality. The owner shall run the wiring to the exterior of the wall facing the service. It will then be connected to the meter and the transmitter by municipal staff.

3. Full Pressure Water System

- a. Properties connecting to the municipal full pressure system must have a 20 mm or ¾ inch shut-off valve located inside the building where the piping exits the ground, prior to the installation of the water meter. The water meter will be supplied by the municipality.

- b. The municipality will supply the meter wire. The homeowner will run the wire to the exterior of the building on the side where the water service enters the building, or where the gas meter is installed. Municipal staff will make the wiring connections to the meter and the transmitter.
- c. All service lines are to be inspected PRIOR to burial by County staff.
- d. Municipal staff must flush all lines prior to use. No services may be turned on by anyone other than municipal staff.

The above information is intended to assist in achieving compliance with the Plumbing Code. It does not cover all aspects of all installations. A current copy of the Plumbing Code should be consulted PRIOR to any work being performed. Property owners are reminded that they are responsible for ALL work performed on their sites. Ensure you get references for any contractors performing work on your property.

It is the homeowner's responsibility to maintain all water and sewer equipment, as well as the piping from their installation to the property connections. This includes fixing ground settlement, line blockage and ensuring frost protection. Lac La Biche County will not be held liable for any damages incurred on private property.

Revised May 12, 2014 JS.